

工程指示 / 要求簡箋(E.I.)

/ 2520 / 20

修改版次：-

J - 852

工程名稱：亞皆老街中電

: 幕牆 -地盆用鐵件 防火棉叉

發件人 : Maggie

發件人 : Ant Yeung

日期 : 30/09/2020

要求提供 / 確認 事項：

- () 初步鋁料 B.M. () 加工拆圖，然後生產 () 尺寸表
- () 正式鋁料 B.M. () 技術上資料 / 指示 () 報價
- () 配件 B.M. () 樣辦或貨品說明書 () 分判合約
- () 其他：_____

內容：

請按加工圖生產幕牆 -防火棉叉送地盆。

銀同：到貨前，請給 MILL CERT, ISO CERT 以及熱浸鋅證書，

請在 2020.10.20 前完成上列要求。

附：1 頁

以上項目為：

- 原合約工程包 原合約工程加 / 減賬 新工程報價

原因：-

分發東莞各部門：

- () 生產技術總監 連附件 () 技術部 連附件 () 生產部 連附件 () 機械設計部 連附件
- () 採購部 連附件 () 生產統籌部 連附件 () 小羅&清 連附件
- () 質檢部 連附件 () 會計部 連附件 () 報關組 連附件 () 其他 楊榮輝 連附件

分發其他分判：

- (v) 水洪 連附件

分發香港各部門：

- () 行政部 連附件 () 會計部 連附件 () 統籌部 連附件 () 工程部地盤科文 連附件 祥哥
- () 採購部 連附件 () QS 部 連附件 () 維修部 連附件 () 其他 _____ 連附件

傳遞編號：

HK / 20

發件人簽署：

項目經理簽署：

- Fire stop and smoke seal shall be installed by the manufacturers' approved applicator.

B. FIRE STOP

- The continuous gap between the facade and the concrete slab edge is to be filled with approved fire-rated insulation compressed to the manufacturers' recommendations and/or other relevant Authority-approved mineral fibre insulation material with a 2-hour fire resistant period.
- Thickness shall be 100mm minimum top to bottom.
- Fire-stop that is in multiple pieces (widths smaller than that supplied by the manufacturer) will not be accepted.
- All fire stop/fire breaks and insulation is to be provided such that visual impact to the face system is minimal and acceptable to the architect.
- Fire Stop width shall be minimum of 25% greater than the gap width and compressed into place.
- ~~Provide impaling clips configured as per fire stop manufacturer's requirements except as noted herein. Clips shall be 1.5mm thick galvanized steel with 50mm minimum width and spaced at maximum 300mm. Impaling clips shall be fastened to floor slab.~~
- Provide additional support in the form of continuous 1.5mm galvanized steel plates at conditions where dimension from floor slab to internal face of facade exceeds 125mm.
- Brand that may be accepted include Thermafire or equivalent.
- Liquid fire stop may be used. Brands / models that may be accepted include Hilti CP-SP WB or equivalent.

✓ A
1.5mm

C. SMOKESEAL

- Provide continuous 1mm thick sealed with smoke seal as part of fire-safing assembly to prevent the passage of smoke between all compartments separated by fire safing assembly.