



工程指示編號：EI / 2617 / 20

修改版次：B

工程編號：J - 852

工程名稱：亞皆老街中電

工程項目：幕牆 Mockup 用玻璃 B.M. (3,5,6/F) T3

收件人：Maggie

發件人：Ant Yeung

日期：03/11/2020

要求提供 /  確認 事項：

- |                                    |                                     |                               |
|------------------------------------|-------------------------------------|-------------------------------|
| <input type="checkbox"/> 初步鋁料 B.M. | <input type="checkbox"/> 加工拆圖，然後生產  | <input type="checkbox"/> 尺寸表  |
| <input type="checkbox"/> 正式鋁料 B.M. | <input type="checkbox"/> 技術上資料 / 指示 | <input type="checkbox"/> 報價   |
| <input type="checkbox"/> 配件 B.M.   | <input type="checkbox"/> 樣辦或貨品說明書   | <input type="checkbox"/> 分判合約 |
| <input type="checkbox"/> 其他：_____  |                                     |                               |

內容：

請按 B.M.訂購(3,5,6/F)用玻璃直送地盤 (T3)

B 版：因顧問再次 Comment 並確認要用 10mm，請取消 A 版的指令。

請在 2020 / 12 / 10 前完成上列要求。

附：1 頁 B.M.，1 頁 B.M 參考.，4 頁加工圖，1 頁位置圖。

以上項目為：

- 原合約工程包                       原合約工程加 / 減賬                       新工程報價

分發東莞各部門：

- ( ) 生產技術總監  連附件    ( ) 技術部     連附件    ( ) 生產部     連附件    ( ) 機械設計部  連附件  
 ( ) 採購部     連附件    ( ) 生產統籌部  連附件  
 ( ) 質檢部     連附件    ( ) 會計部     連附件    ( ) 報關組     連附件    ( ) 其他 楊榮輝  連附件

分發香港各部門：

- ( ) 行政部  連附件    ( ) 會計部  連附件    ( ) 統籌部  連附件    ( ) 工程部地盤科文  連附件 祥哥  
 ( ) 採購部  連附件    ( ) QS 部  連附件    ( ) 維修部  連附件    ( ) 其他 \_\_\_\_\_  連附件

傳遞編號：

HK / 20

發件人簽署：

項目經理簽署：



**MATERIAL / SAMPLE SUBMISSION FORM**

To : **Mr Brian Leung / Ms Yoanna Chan / Mr Nigel Lo**  
**Meinhardt Façade Technology (HK) Ltd**  
22/F Great Smart Tower,  
230 Wanchai Road,  
Wan Chai, Hong Kong

No. MS/A/196 (Rev. 0)

Date: 29 September 2020

REQUIRED APPROVAL DATE: 12 October 2020

Ref. J3860/304.6/D06347

We submit the following material for your comment / approval by the date indicated above.

Sub-Contractor / Trade: Midi Aluminium Fabrication Ltd., / Curtain Wall, Aluminium Windows and Louvres, Aluminium Cladding and Glass Balustrade

Material Description: Submission of Glass Samples for On-site Mock up and Bulk Order (MS041)

**Comply fully w/ Specification**  
MFT's specification

**Not comply fully with Specification (Deviation Listed herein)**  
N.A.

Equipment Originally Offered

Type : N.A.  
Manufacturer : N.A.  
Origin : N.A.  
Model No : N.A.

Equipment Offered

Type : Glass  
Manufacturer : Avic Sanxin  
Origin : China  
Model No : Refer to attached Midi's Letter

Reason for change if any : N.A.

Location for use: Precast Windows, In-situ Windows & Doors, Curtain Wall, Glass Cladding, Balustrade, Skylight

Enclosures:  Catalogue  Data / Specification  Certificate / Approval  
 Test Report  Material Sample  Installation Drawing  
 Job Reference  Schedule  Other (specify):

Remarks: The sample was received and kept on site on 23 September 2020.

cc	<input checked="" type="checkbox"/> Pacific Shine	-	Mr Billy Tang / Mr Kocher Wong / Mr Edwin Chow / Mr Simon Chung / Mr Ross Pau / Mr Ken Ng / Mr Wyman Fong / Mr Jimmy Cheung / Mr C F Lee / Mr Peter Chong
	<input checked="" type="checkbox"/> AGC	-	Ms Grace Cheng / Mr Raymond Ho
	<input type="checkbox"/> ARUP (Stru)	-	Mr Johnson Po / Mr Don Ho / Ms Jessy Zhang
	<input type="checkbox"/> W&O	-	Mr Nier Chan / Mr Anson Lau
	<input checked="" type="checkbox"/> Arcadis	-	Ms Brenda Mok / Ms Emily Chu
	<input type="checkbox"/> AXXA	-	Ms Siunan Hung / Ms Sammy Tang / Mr Oscar Leung / Ms Yvonne Yau
	<input type="checkbox"/> ARUP (Traffic)	-	Ms Carmen Chu / Mr Eddy Cheung
	<input type="checkbox"/> WSP	-	Ms Anthea Ng / Mr Dennis Tse
	<input type="checkbox"/> RE	-	Mr Andrew Tai / Mr Yang Li / Mr Oscar Tam
	<input checked="" type="checkbox"/> MFT RE	-	Ms Cosimo Wong / Mr Neo Wong
	<input checked="" type="checkbox"/> OSR	-	Mr K M Pang / Mr H T Tseung / Mr Poon Tsz Kit / Mr S T Chan / Mr Ben Li
	<input type="checkbox"/> BSI (Sino)	-	Mr Kelvin Tam
	<input type="checkbox"/> RBSE (W&O)	-	Mr Kevin Lee
	<input type="checkbox"/> GECC	-	LCW / QS / Structural Team
	<input checked="" type="checkbox"/> S/C	-	Midi (By Email)

Encl

Architect's / Consultant's Reply

Approved (A)  Approved with comment (B)  Approved with comment & resubmit (C)  Rejected (D)

Comments : No comment on glass thickness. Performance data subject to sustainability consultant's comment. Appearance subject to client's and AGC comment. Please advice the schedule and arrangement of heat soak test.

Signed : PP:  Designation : MFT Date : 19 Oct 2020  
Remarks :  w/encl.  w/o encl