

工程指示 / 要求簡箋 ENGINEER INSTRUCTIONS(E.I.)

| | | | |
|---------|------------------------|-------|------------|
| 工程指示編號: | EI- 5599B | 修改版本: | B |
| | HK- | | |
| 工程編號: | J 853 | 工程名稱: | 大窩坪 (延坪道) |
| 收件人: | Maggie Lor | 發件人: | Edwin Ho |
| 工程項目: | T3 後裝窗大貨 (修訂B: 玻璃片種修訂) | 日期: | 20/02/2023 |

| | | |
|---------------------------------|--|------------------------------------|
| <input type="checkbox"/> 原合約工程包 | <input type="checkbox"/> 原合約工程加 / 減賬 QT- | <input type="checkbox"/> 新工程報價 QT- |
|---------------------------------|--|------------------------------------|

| | |
|----------------|-----------|
| 信件批核號碼/圖紙參考編號: | 批核模具圖紙編號: |
| 客戶指示附件: | 管理內部批簽署: |

| | | |
|---|-------------------------------------|-------------------------------|
| <input type="checkbox"/> 初步鋁料 B.M. | <input type="checkbox"/> 加工拆圖, 然後生產 | <input type="checkbox"/> 尺寸表 |
| <input type="checkbox"/> 正式鋁料 B.M. | <input type="checkbox"/> 技術上資料/指示 | <input type="checkbox"/> 報價 |
| <input checked="" type="checkbox"/> 配件 B.M. | <input type="checkbox"/> 樣辦或貨品說明書 | <input type="checkbox"/> 分判合約 |
| <input type="checkbox"/> 其他: | | |

內容: 根據根EI修訂GL05片種為10mm HS +12A +10mm Clear Tempered Glass with Acid Etched#3 , 沿用貴司提供之樣板Sample N. 20210909019之規格, 特此通知。



完成上列要求日期: ASAP

國內

| | | | | | |
|---------------------------------|---|---|---|--------------------------------|------------------------------|
| <input type="checkbox"/> 生產技術總監 | <input type="checkbox"/> 連附件 | <input type="checkbox"/> 技術部 | <input type="checkbox"/> 連附件 | <input type="checkbox"/> 生產部 | <input type="checkbox"/> 連附件 |
| <input type="checkbox"/> 採購部 | <input type="checkbox"/> 連附件 | <input checked="" type="checkbox"/> 生產統籌部 | <input checked="" type="checkbox"/> 連附件 | <input type="checkbox"/> 報關組 | <input type="checkbox"/> 連附件 |
| <input type="checkbox"/> 質檢部 | <input type="checkbox"/> 連附件 | <input type="checkbox"/> 會計部 | <input type="checkbox"/> 連附件 | <input type="checkbox"/> 機械設計部 | <input type="checkbox"/> 連附件 |
| <input type="checkbox"/> 香港辦 | <input checked="" type="checkbox"/> 連附件 | <input type="checkbox"/> 其他: | | | |

香港

| | | | | | | | |
|------------------------------|------------------------------|------------------------------|------------------------------|--|---|------------------------------|------------------------------|
| <input type="checkbox"/> 行政部 | <input type="checkbox"/> 連附件 | <input type="checkbox"/> 會計部 | <input type="checkbox"/> 連附件 | <input type="checkbox"/> 統籌部 | <input type="checkbox"/> 連附件 | <input type="checkbox"/> 工程部 | <input type="checkbox"/> 連附件 |
| <input type="checkbox"/> 採購部 | <input type="checkbox"/> 連附件 | <input type="checkbox"/> QS部 | <input type="checkbox"/> 連附件 | <input checked="" type="checkbox"/> 地盤管理 | <input checked="" type="checkbox"/> 連附件 | <input type="checkbox"/> 維修部 | <input type="checkbox"/> 連附件 |

| | |
|------------------|--|
| *發件人簽署: Edwin Ho | *組別成員批核簽署:  |
| 傳遞編號: | 項目經理簽署:  |

midi@midiltd.com.hk

From: midi@midiltd.com.hk <midi@midiltd.com.hk>
To: annesun@avicsgt.com
Copies to: edwinsowin@gmail.com, Waiho.hcw.midi@gmail.com
Date sent: Mon, 06 Feb 2023 11:54:34 +0800

Dear Anne,

GL05為沿用Sample No. 20210909019之規格，可根據以上規格恢復生產，特此通知。

Edwin HO

From: midi@midiltd.com.hk <midi@midiltd.com.hk>
To: annesun@avicsgt.com
Copies to: edwinsowin@gmail.com, Waiho.hcw.midi@gmail.com
Date sent: Tue, 31 Jan 2023 14:24:13 +0800

Dear Anne,

經核對後，GL05玻璃需先暫時停止生產。

另外需重新提供GL05玻璃樣板2塊，藥水砂做在第3面，其實標準跟GL05(D21032009)一樣。

Edwin HO

From: j853@midiltd.com.hk <j853@midiltd.com.hk>
To: annesun@avicsgt.com
Copies to: edwinsowin@gmail.com
Date sent: Tue, 31 Jan 2023 11:30:01 +0800

Dear Anne,

經核對後，GL05片種跟落單一様。另外EI5597A 至到 EI5602A內之GL01沒有大小片之分。

Edwin HO

From: "midi@midiltd.com.hk" <midi@midiltd.com.hk>
To: j853@midiltd.com.hk
Date sent: Mon, 30 Jan 2023 10:22:09 +0800

----- Forwarded message follows -----

Date sent: Mon, 30 Jan 2023 10:16:01 +0800
From: 孙美玲 <annesun@avicsgt.com>
To: midipur <midipur@midiltd.com.hk>, midi <midi@midiltd.com.hk>
Copies to: liangsy-2006 <liangsy-2006@163.com>
Subject: 回复: Fw:EI5597A TO EI5602A & PR45760

Eva ,

新年好！麻烦帮我确定一下GL05这款玻璃，到底是强化+强化还是半强化+强化？因为落单跟合约品种不同。
还有再确认下GL01款有没有大小片，因为没有提供图纸，我看不出，谢谢！

annesun@avicsgt.com

发件人：梁少颜
发送时间：2023-01-19 13:36
收件人：annesun
主题：Fw:EI5597A TO EI5602A & PR45760
小孙：
请安排下单。

----- 转发邮件信息 -----

发件人："midipur@midiltd.com.hk" <midipur@midiltd.com.hk>
发送日期：2023-01-17 14:34:25
收件人：liangsy-2006@163.com
主题：EI5597A TO EI5602A & PR45760
少，

查收附件K安排修改加工热菁鞍才偶庸，xx!

Maggie


MIDI Aluminium Fabricator Ltd., Tel:(852) 2348 9211, Fax:(852) 2772 7666

Disclaimer: The information contained in this e-mail is confidential and is intended solely for the addressee. If you are not the intended recipient, please notify the sender immediately and delete this e-mail from your system. Any unauthorised use, disclosure, copying, printing, forwarding or dissemination of any part of this information is prohibited. MIDI does not accept responsibility for the content of any e-mail transmitted by its staff for any reason other than bona fide business purposes. Any information that is not transmitted via secure tamper-proof technology should not be relied upon, unless advised or agreed otherwise in writing by an authorised representative of MIDI

----- End of forwarded message -----


MIDI Aluminium Fabricator Ltd., Tel:(852) 2348 9211, Fax:(852) 2772 7666

Disclaimer: The information contained in this e-mail is confidential and is intended solely for the addressee. If you are not the intended recipient, please notify the sender immediately and delete this e-mail from your system. Any unauthorised use, disclosure, copying, printing, forwarding or dissemination of any part of this information is prohibited. MIDI does not accept responsibility for the content of any e-mail transmitted by its staff for any reason other than bona fide business purposes. Any information that is not transmitted via secure tamper-proof technology should not be relied upon, unless advised or agreed otherwise in writing by an authorised representative of MIDI


海控特玻
Hakong SGT
 建築工程特玻
 Construction Special Glass

公司名稱: 海控特玻
 地址: 香港新界沙田區大圍廣源街1號
 電話: 3426 1111
 傳真: 3426 1112
 網址: www.hakongsgt.com

工程名稱: J850 旺角
 Project: J850 WING KONG
 樣品編號: K20210909019 檢驗員 (QC)
 Sample No.: K20210909019 Inspector (QC)


MIDI ALUMINIUM FABRICATOR LTD.
 Units 6, 7, 8, Salween Industrial Centre, 1st Floor, 610 Cheung Kwai Ping Eng Street, Kowloon

Project: SX11 6542, Yin Ping Road, Tai Wu Ping, Hong Kong (Tower)
 Subject: GLS - Frosted Tempered Glass Sample
 (Clear Glass + 12mm Air + 10mm Frost Glass (G1))

Brand: SAXIN
 Sample Code: K20210909019
 Letter ref.: MC248755853
 Date: 27th September 2021

PEIYU YIP
 (WTP)
 Approved
 on
 26 Nov 2021